



Tom Barrett  
Mayor

Bevan K. Baker, FACHE  
Commissioner of Health

Vivian T. Chen, MSW, ScD  
Health Operations Director

## Health Department

## Consumer Environmental Health

Frank P. Zeidler Municipal Building, 841 North Broadway, Room 304, Milwaukee, WI 53202-3653 Phone: (414) 286-3674 Fax: (414) 286-5164  
web site: [www.milwaukee.gov/health](http://www.milwaukee.gov/health)

# Routine Food Inspection

BEST BUY STORES,L.P.(PARTNAME) BEST BUY STORES, LIMITED PARTNERSHIP  
(BUSINESSNAME)  
8875 N 76TH ST  
MILWAUKEE, WI 53223

February 21, 2008

The following list of violations of the Wisconsin Administrative Code as adopted by reference in the Milwaukee Code of Ordinances Chapter 68, and/or other City ordinance(s) must be corrected as soon as possible but not later than the date specified. A re-inspection fee may be assessed if the violation is not corrected by that date. An inspection fee may be charged for any repeat violations.

Fee Amount: \$0.00

Code Number	Description of Violation	Correct By
5-103.11	No hot water is available for hand washing at the restroom sinks (men's, women's, and the restroom in the install area). All hand sinks are required to have hot water available for handwashing within 20 seconds of turning the faucet on. Provide hot water for all the handsinks.	02/21/2008
5-202.11	There is no backflow device installed on the mop sink in the back storage area. A backflow preventer is required to be installed at all mopsinks to prevent waste water backflow into the water supply. Install a backflow preventer on the mop sink faucet.	03/06/2008

### Inspection Notes

On 2/21/2008, I served these orders upon BEST BUY STORES,L.P.(PARTNAME) BEST BUY STORES, LIMITED PARTNERSHIP (REGD. N/

Inspector Signature (Inspector ID: 66)

Operator Signature

Please be advised that this document is subject to public review under open records law. - Wis. Statutes section 19.35(1)(a)